



Amesbury Fire Rescue

Chief Jonathan R. Brickett
brickettj@amesburyma.gov

Assistant Chief Glenn A. Fournier
fournierg@amesburyma.gov

Deputy Chief David B. Mather
matherd@amesburyma.gov

Ventless Gas Stove Installation Fire Rules and Regulations

- 1. Has to be Massachusetts approved**
- 2. Can not be installed in a bedroom or bathroom**
- 3. Needs an ODS sensor – oxygen depletion sensor on it**
- 4. Need to have a smoke detector and CO (carbon monoxide) detector in the room**
- 5. Needs to be installed per manufacturer's recommendations.**
- 6. Need to schedule a pre-inspection and a post inspection to be done by fire department.**