



MILLENNIUM ENGINEERING, INC.
Land Surveyors and Civil Engineers

To: Nipun Jain, Planner
Amesbury Planning Board

From: Eric Botterman, P.E
Millennium Engineering, Inc.

Date: July 8, 2016

Subject: Eastern Lights Subdivision
Utility Inspection Memorandum for
37 Middle Road, Amesbury MA.

The following provides brief review of utility inspections requirements for utilities previously installed at the subject location:

Stormwater Facilities

Pipes and structures will be visually inspected at manholes and outlets for conformance to standard municipal installation practices and generally accepted construction practices.

Water Mains

Water mains will be pressure tested in conformance with AWWA C651 and standard municipal testing practices.

Sewer Mains

Sewers mains will be pressure tested in conformance with the Uni-Bell Recommended Practices for Low Pressure Air Testing of Installed Sewer Pipe. UNI-B-6. Manholes will be vacuum tested in accordance with standard municipal testing practices.

END.