

Year 2018 Water Testing

The Mass. Department of Public Health currently accepts an E.coli count of <235/100ml in fresh water bathing areas.

| | Date 6/20/2018 | Date 6/27/2018 | Date 7/2/2018 | Date 7/11/2018 | Date 7/18/2018 | Date 7/25/2018 |
|----------------------|-------------------|-------------------|-------------------|-------------------|-------------------|-------------------|
| Lake Gardner Beach | 13 | 5 | 12 | 5 | 23 | 35 |
| Glen Devin | 7 | 20 | 31 | 86 | 58 | 5 |
| Camp Bauercrest | 3 | 4 | 5 | 71 | 63 | 2 |
| Lake Attitash | 12 | 2 | 1 | <1 | 54 | 6 |
| Tuxbury Pond RV Park | 5 | 15 | 3 | 2 | 16 | <1 |
| | Date 8/1/2018 | Date 8/9/2018 | Date 8/15/2018 | Date 8/22/2018 | Date 8/29/2018 | |
| Lake Gardner Beach | 27 | 72 | 261 | 5 | 12 | |
| Glen Devin | 11 | 1,553 | 261 | 22 | 16 | |
| Camp Bauercrest | 20 | 2 | 3 | 1 | n/a | |
| Lake Attitash | <1 | 1 | 12 | 5 | <1 | |
| Tuxbury Pond RV Park | 1 | 1 | 120 | <1 | <1 | |



**TESTING FOR THE SEASON
IS COMPLETED.**

Beach Water Testing performed by: BioMarine - Gloucester, MA